


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

HGP No : 41/2025-26

Date: 30/04/2026

It is certified that an inspection team headed by **Munirangappa M, PDO** from Haragadde Panchayat inspected the **GENIUS TECHNO SCHOOL**, #53, Surya city Phase ii, Yellammanapalya, Anekal 562106 on 22/04/2026 and on the basis of **Water Test Report** (Attached) bearing no MCL/GTS/9332 dated 13/03/2026 of Met – Chem Laboratories(iso9001:2015) certified that the **GENIUS TECHNO SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till 3 years.


ಪಂಚಾಯತಿ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ
ಹಾರಗದ್ದೆ ಗ್ರಾಮ ಪಂಚಾಯತಿ
ಜಿಗಣಿ ಪೂಜೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು,
ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ.

To:

Genius Techno School

Surya city Phase ii, Anekal,

Bangalore 562106

Met - Chem Laboratories

(ISO 9001 : 2015 Certified Lab)

H.O. : # 289, "Ashirwad" 12th Cross, 5th Main, M.S. Ramaiah Nagar, Bangalore - 560 054.

Ref.No.MCL/ GTS / 9332

Date:-13.02.2026

To,
M/s. Genius Techno School
#53,surya city phaseII,
Yellammanapalaya, Anekal,
Bangalore-562106.

TEST - REPORT


This is to certify that the water sample submitted by the above party has been analyzed by us
With the following results. (Lab Ref.No: 11860 dated 12.02.2026)

Sample Mark:- Bore well water.

No	Parameters	Test Protocol	Units	Results	IS:10500-2012	
					Acceptable Limit	Permissible Limit
1	Colour	MCL/SOP/Colour:2019	Hazens	02.00	05.00	15.00
2	Turbidity	IS:3025(P-10)-1984RA-2017	NTU	00.92	01.00	05.00
3	pH value	IS:3025(P-11)-1983RA-2017	---	07.90	6.5-8.5	6.5-8.5
4	Odour	IS:3025(P-5) 1983RA-2017	---	Agreeable	Agreeable	Agreeable
5	Total dissolved Solids	IS:3025(P-16)-1984RA-2017	mg/L	651.00	500	2000
6	Phenolphthalein Alkalinity as CaCO ₃	IS:3025(P-23)-1986RA-2019	mg/L	NIL	200	600
7	Total Alakalinity as CaCO ₃	IS:3025(P-23)-1986RA-2019	mg/L	302.28	200	600
8	Total Hardness as CaCO ₃	IS:3025(P-21)-2009RA-2019	mg/L	287.71	200	600
9	Calcium as Ca	IS:3025(P-40)-1991RA-2019	mg/L	81.35	75	200
10	Magnesium as Mg	IS:3025(P-46)-1994RA-2019	mg/L	20.49	30	100
11	Total Suspended Solids (TSS)	MCL/SOP/TSS:2019	mg/L	01.00	01.00	<05.00
12	Iron as Fe	IS:3025(P-53)-2003RA-2019	mg/L	00.14	0.30	<0.30
13	Chlorides as Cl	IS:3025(P-32)-1988RA-2019	mg/L	120.49	250	1000
14	Sulphates as SO ₄	IS:3025(P-24)-1986RA-2019	mg/L	65.50	200	<400
15	Nitrates as NO ₃	MCL/SOP/NO ₃ :2019	mg/L	07.22	<45	<45
16	Flouride as F	IS:3025(P-60)-2008RA-2019	mg/L	00.56	<01.00	<01.50
17	Conductivity	IS:3025(P-14)-1984RA-2019	µs/cm	1010.00	2250	2250


Remarks: Potable for tested parameters


Tested By: S. Nalmadha

Verified By: 

- The result declared above pertains only to the tested sample and reported parameters.
- Samples tested will be disposed off after reporting, unless specified
- Total liability of our laboratory is limited to the Invoice amount
- This report cannot be reproduced except in full without prior written permission
- Sampling is not done by us & this report cannot be used as an evidence in any Court of Law.

For Met- Chem Laboratories,


(Authorized signatory)



Met-Chem Laboratories

(ISO:9001-2015 & NABL Accredited Lab)

Analytical & Consulting Chemists

H.O. #. 289 "Ashirwad" 12th Cross, 5th Main, M.S.R.Nagar, Bangalore - 560 054.

Telefax:-(080) 2360

5701

(m): 95389 74672,

94483 18372

E-mail : metchemlaboratory@gmail.com

merwade_ae@yahoo.co.in

TAX INVOICE

To

M/s.Genius Techno school

53, surya city phase II,

Yellammanapalaya,Anekal,

Bangalore=562106.

Client GST No: NA

Invoice No. : 1005

Date : 13.02.2026

Sr. No.	Particulars	Amount
	Analysis charges of water samples vide report No.:MCL/ GTS / 9332 Dated 12.02.2026 @2500 Per sample	2,500.00
	Total:	2,500.00
	Tax Added	
	Add SGST 9.00%	225.00
	Add CGST 9.00%	225.00
	Add IGST 0.00%	

Rs. Two thousand and Nine hundred fifty Only

To Pay 2,950.00

Bank details for RTGS/NEFT

A/c Name :

Met-Chem Laboratories

A/c No.3625 0021 0010 9201

IFSC CODE - PUNB0362500,

PUNJAB NATIONAL BANK,

RMV EXTENSION BRANCH,

BANGALORE - 560054.

PAN No: ABKPM0535D

SAC Code 998346

GSTIN 29ABKPM0535D1ZT

For Met-Chem Laboratories

Authorised Signatory

(subject to bangalore jurisdiction)